

# Emission Test Certificate

Monday 04<sup>th</sup> November 2019

Supplier: HQ Wood Pty Ltd (51 Atlantic Drive, Keysborough, VIC, 3173, Australia)

Sample Description: Sunstar Engineered Flooring

Date Tested: October 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<p><b>Green Building Council of Australia</b> Green Star Design &amp; As Built V1.2 - 13.1.2B &amp; 13.2B Green Star Interiors V1.2 - 12.1.2B</p>	<p><b>Sunstar Engineered Flooring</b></p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.059 mg/m<sup>2</sup>/hr*</p>
<p>Formaldehyde Emission Rate Limit: ≤0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: &lt;0.003 mg/m<sup>2</sup>/hr*</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Luke Morley  
BSc(Biotech)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

V1910062